

**St Anne Stanley CE Primary School Accessibility Plan 2017 – 2020**  
**Improving the Physical Access at St Anne Stanley CE Primary School**

An Access Audit was carried out on 5.01.2017

Access report ref	Priority	Activity	Responsibility	Short term	Med term	Long term	Cost	Outcome/Progress
1.	Route leading into school from gate is not level.	Needs levelling to provide safer access.	HT	X				Work has been <b>completed</b> . Route into school is now level.
2.	Threshold at entrance is 20mm.	Recommended to be 15mm with a chamfer.	HT	X				<b>Completed</b> . Threshold entrance now 15mm with a chamfer
3.	No highlighted disabled parking bay.	To be provided inside school gates when requested and if in line with pupil safety.	HT			X		Work arranged for summer term. N/A – Site staff to support with parking if and when requested.
4.	Disabled toilets	Should be provided with backrests.	HT	X				<b>Completed</b> . Back rest received installed during Easter break.

6.	Door Handles	Some need to be between 900mm and 1000mm from floor level.	HT		<b>X</b>			
8.	Obstruction in corridors	Corridors should be kept free from obstruction esp near disabled toilet.	HT	<b>X</b>				<b>Completed.</b> All obstructions removed.
9.	Handrails on stairs	Some need extending 300mm beyond last steps.	HT		<b>X</b>			<b>Completed .</b> All handrails have been extended.
10.	Emergency lighting	Additional lighting to be considered to bring levels to min of 10 lux.	HT			<b>X</b>		<b>Completed.</b> Additional lighting in place.
11.	Handrail	To be provided into the school up the ramp.	HT	<b>X</b>				Work arranged for Easter break.

## St Anne Stanley CE Primary School Accessibility Plan 2017 – 2020

### Improving the Curriculum Access at St Anne Stanley CE Primary School

Target	Strategy	Outcome	Responsibility	Short term	Med term	Long term	Achievement/Progress
Audit of needs of current pupils.	Staff training to suit those needs.	Teachers are aware of relevant current	SLT			<b>X</b>	<b>Complete.</b> The needs of all learners have been met.

		issues. Report back at pupil progress meetings.				Ongoing discussions during pupil progress meetings.
Diabetes/asthma/stoma training	Training by specialist nurses.	Individual pupils supported.	SENCo	<b>X</b>		<b>Completed.</b> Arranged annually unless any changes. Training is up to date.
RAS awareness training	Staff training		SENCo	<b>X</b>		<b>Complete.</b> Staff training has been undertaken and staff are aware of procedures to follow.
Specialised areas in classrooms	Safe spaces, concentration stations organised in individual classrooms	Emotional/educational needs of individual children supported.	SENCO	<b>X</b>		<b>Completed.</b> Safe spaces for individual classrooms have arranged for individual children.

## St Anne Stanley CE Primary School Accessibility Plan 2017 – 2020

### Improving the Delivery of Written Information at St Anne Stanley CE Primary School

An Access Audit was carried out on 5.01.2017

Target	Activity	Responsibility	Short term	Med term	Long term	Cost	Outcome/Progress
Review signage around school	Audit signage around school to ensure accessibility to all.	SEN Co/HT	<b>X</b>				<b>Completed.</b> Audit undertaken – appropriate signage in place.
Audit provision for dyslexic pupils and staff	Provide coloured paper for photocopying.	SLT	<b>X</b>				<b>Completed.</b> Coloured paper available for dyslexic pupils. Quotes arranged for whole school to have the same provision.
Raise awareness of font size and page layouts to support pupils with visual impairments.	Inset/training for staff.	SEN Co	<b>x</b>				<b>Completed.</b> Staff aware of support needed if required.